

Fire

1. All dedicated fire water supplies prior to backfilling.
  2. Above ceiling inspection prior to the ceiling being installed if there are sprinklers or mechanical devices in the ceiling space.  
Exception: R-3 and R-4 Use Groups.
  3. Pressure test on all new sprinkler work per NFPA 13.
  4. A function test on all new fire alarm systems and components.  
Exceptions: Any initiating device or indicating device replaced during routine maintenance does not require an inspection.
  5. Fireplace prior to enclosing the unit.
  6. A final inspection when everything is completed and operating, this includes heating units.
- Required special inspections. The applicant by accepting the permit will be deemed to have consented to these requirements.
  - A final inspection is required by all applicable sub code before a final Certificate of Occupancy or approval may be issued.*** Any violations of the approval plans and/or permit will be noted and the holder of the permit notified of discrepancies.

If you do not understand this information, please ask.